



CONCRETE SIDEWALK NOTES:

1. PLACE A TOOLED JOINT 1/8 INCH WIDE AND AT LEAST 1/3 OF THE DEPTH AT 5.0 FT O.C.
2. PLACE AN EXPANSION JOINT EVERY 20.0 FT FOR SIDEWALK AND CURBS.
3. BROOM FINISH WITH SMOOTH TROWEL EDGES.
4. SIDEWALK SHALL BE CONSTRUCTED IN ACCORDANCE WITH VAOT STANDARDS, SECTION 618.
5. CONCRETE SHALL BE THICKENED TO 8 INCHES THROUGH ALL RESIDENTIAL AND COMMERCIAL DRIVES.
6. CURB AND SIDEWALK SHALL BE SEPARATED BY A 1/2 INCH PREMOLDED JOINT FILLER WHERE THERE IS NO GREEN BELT.



CITY OF WINOOSKI
PUBLIC WORKS DEPARTMENT
27 WEST ALLEN STREET, WINOOSKI VT 05404

STANDARD SPECIFICATIONS

DRAWING TITLE:
CONCRETE SIDEWALK AND CURB

DATE: 10/1/18

SCALE: NTS

DRAWING #: ST-1